

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
LISTING SERVICE**

**LISTING No.** 7170-1657:145

Page 1 of 2

**CATEGORY:** Control Unit (High-Rise)

**LISTEE:** GE Security, Inc., 8985 Town Center Parkway, Bradenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

**DESIGN:** Model ESA 2000 system. Local, auxiliary, coded or non-coded, remote station and central station service; audio evacuation and emergency voice paging & fireman phones; manual or automatic, waterflow and sprinkler supervisory (local only) service. Refer to listee's data sheet for detailed product description and operational considerations. Minimum system:

|                      |                                    |
|----------------------|------------------------------------|
| 2025-000             | Base Panel                         |
| 2025-700/701/702/704 | CPU Units                          |
| 2016-001             | Display Module                     |
| 2004-001/302         | Page Zone Module                   |
| 2004-002             | 30W Amplifier                      |
| 2005-001             | Telephone Zone Module              |
| 2006-001             | Tone Module                        |
| 2006-401             | Microphone Module                  |
| 2006-402             | Master Microphone                  |
| 2006-501/502         | Master Telephone Module/Handset    |
| 2006-601             | Microphone/Telephone Drop Assembly |
| 2030-402             | Audio Power Supply                 |

**OPTIONS:** Refer to listee's data sheet for the description of optional accessories. When required, accessories shall be CSFM listed. This listing includes:

2001-001, 2002-001/002/401, 2003-401, 2006-003/004, 2010-101/102 2010-104/201/202/X202/401, 2016-002/901, 2020-001, 2030-001/900, 8558-401/501/B601/B901, 6296B-100, 6297B-100/R100/300, 6298B-R100.

**INSTALLTION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

08-15-05

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a control unit for use in high-rise structures when use with separately listed compatible initiating and indicating devices.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

- NOTE:**
1. Security and other non-fire functions were not examined.
  2. Formerly 7170-1591:145, 7170-1388:144 and 7170-0073:146

08-15-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 26, 2006**

*Listing Expires **June 30, 2007***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager